

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090 Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini
Date Received: 10/07/2020
Date Final: 10/15/2020

Summary

This summary is provided for your convenience. Complete report on the following pages.

General Comments:

Acmetonia Elementary School

Environmental Culture Test-Legionella				
Location	Result	Concentration	Species	
AE-01. Kitchenette Sink-A05 Work/Mail Room	Not Detected			
AE-02. Restroom Sink-A13 Rest	Not Detected			
AE-03. Boy's Restroom-2nd Grade	Positive	1.5 CFU/mL	L. pneumophila, serogroup 6	
AE-04. Office Sink-Room A33	Not Detected			
AE-05. Classroom Sink-Room B33	Not Detected			
AE-06. Kitchenette Sink-Business Office	Positive	20.0 CFU/mL	L. pneumophila, serogroup 6	
AE-07. Restroom Sink-By Stairs A	Positive	10.0 CFU/mL	L. pneumophila, serogroup 6	
AE-08. Classroom Sink-Room B40	Not Detected			
AE-09. Classroom Sink-Room C48	Not Detected			
AE-10. Girl's Restroom-3rd Grade	Positive	2.0 CFU/mL	L. pneumophila, serogroup 6	
AE-11. Boy's Restroom-3rd Grade	Not Detected			
AE-12. Girl's Restroom-E-Wing	Positive	7.0 CFU/mL	L. anisa (Blue-white Legionella sp.)	
AE-13. Boy's Restroom-E-Wing	Positive	40.0 CFU/mL	L. pneumophila, serogroup 6	
AE-14. Classroom Restroom Sink-Room E115	Not Detected			



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090 Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini
Date Received: 10/07/2020
Date Final: 10/15/2020

Environmental Culture Test-Legionella

Location	Result	Concentration	Species
AE-15. Classroom Sink-Room E110	Not Detected		
AE-16. Kitchenette Sink-Faculty Room C54	Not Detected		
AE-17. Kitchen Sink-Kitchen C57	Not Detected		
AE-18. Hot Water Heater-Mechanical Room D61	Not Detected		
AE-19. Classroom Sink-Room D75	Positive	90.0 CFU/mL	L. pneumophila, serogroup 6
AE-20. Classroom Restroom Sink-Room A19	Positive	160.0 CFU/mL	L. pneumophila, serogroup 6

Approved by: Marisa Hirsh

Janet E. Stout, Ph.D.

Laboratory Director, Special Pathogens Laboratory



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090

Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini Date Received: 10/07/2020

Date Final: 10/15/2020

AE-01. Kitchenette Sink-A05 Work/Mail Room Location:

2010-00220.001 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

10/07/2020 Date Collected:

Water Sample Type: Time Collected: 8:28 am

Status: Complete 10/15/2020

Location: AE-02. Restroom Sink-A13 Rest

2010-00220.002 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

10/07/2020 Date Collected:

Water Sample Type: Time Collected: 8:30 am

10/07/2020

8:32 am

10/07/2020

Water

8:34 am

Water

Status: Complete 10/15/2020

Date Collected:

Sample Type:

Time Collected:

Date Collected:

Sample Type:

Time Collected:

Status: Complete 10/15/2020

Location: AE-03. Boy's Restroom-2nd Grade

2010-00220.003 Sample ID:

Receipt Temp:

Test Requested: **Environmental Culture Test-Legionella**

Result: **Positive** Concentration: 1.5 CFU/mL

Species: L. pneumophila, serogroup 6

AE-04. Office Sink-Room A33 Location:

2010-00220.004 Sample ID:

Receipt Temp: Test Requested: Environmental Culture Test-Legionella Status: Complete 10/15/2020

Result: **Not Detected**

AE-05. Classroom Sink-Room B33 Date Collected: 10/07/2020 Location:

2010-00220.005 Water Sample Type: Sample ID: 8:37 am Receipt Temp: Time Collected:

Test Requested: Environmental Culture Test-Legionella Status: Complete 10/15/2020

Result: **Not Detected**



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090

Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini Date Received: 10/07/2020

Date Final: 10/15/2020

AE-06. Kitchenette Sink-Business Office Location:

2010-00220.006 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Positive** Concentration: 20.0 CFU/mL

Species: L. pneumophila, serogroup 6

Location: AE-07. Restroom Sink-By Stairs A

Sample ID: 2010-00220.007 Receipt Temp:

Environmental Culture Test-Legionella Test Requested:

Result: **Positive** 10.0 CFU/mL Concentration:

Species: L. pneumophila, serogroup 6

AE-08. Classroom Sink-Room B40 Location: 2010-00220.008

Sample ID: Receipt Temp:

Test Requested: **Environmental Culture Test-Legionella**

Result: **Not Detected**

Location: AE-09. Classroom Sink-Room C48

2010-00220.009 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

Location: AE-10. Girl's Restroom-3rd Grade

2010-00220.010 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Positive Result: Concentration: 2.0 CFU/mL

L. pneumophila, serogroup 6 Species:

Water Sample Type:

Time Collected: 8:40 am

Status: Complete 10/15/2020

Date Collected:

Date Collected: 10/07/2020

Water

10/07/2020

Sample Type: 8:42 am Time Collected:

Status: Complete 10/15/2020

10/07/2020 Date Collected:

Water Sample Type: 8:44 am Time Collected:

Status: Complete 10/15/2020

10/07/2020 Date Collected:

Water Sample Type: 8:45 am

Time Collected:

Status: Complete 10/15/2020

Date Collected:

10/07/2020 Water

Sample Type: 8:46 am Time Collected:

Status: Complete 10/15/2020



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090

Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini Date Received: 10/07/2020

Date Final: 10/15/2020

AE-11. Boy's Restroom-3rd Grade Location:

2010-00220.011 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

10/07/2020 Date Collected:

Water Sample Type: Time Collected: 8:48 am

Status: Complete 10/15/2020

Location: AE-12. Girl's Restroom-E-Wing

2010-00220.012 Sample ID:

Receipt Temp: Test Requested:

Environmental Culture Test-Legionella

Result: **Positive** Concentration: 7.0 CFU/mL

Species: L. anisa (Blue-white Legionella sp.)

AE-13. Boy's Restroom-E-Wing Location:

2010-00220.013 Sample ID:

Receipt Temp:

Environmental Culture Test-Legionella Test Requested:

Result: **Positive** Concentration: 40.0 CFU/mL

Species: L. pneumophila, serogroup 6

Location: AE-14. Classroom Restroom Sink-Room E115

2010-00220.014 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

Location: AE-15. Classroom Sink-Room E110

2010-00220.015 Sample ID:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Not Detected**

10/07/2020 Date Collected: Sample Type:

Water

Time Collected: 8:50 am

Status: Complete 10/15/2020

Date Collected: 10/07/2020

Water Sample Type:

Time Collected: 8:51 am

Status: Complete 10/15/2020

Date Collected:

Sample Type: Time Collected:

Status: Complete 10/15/2020

Date Collected:

Sample Type:

Time Collected:

Status: Complete 10/15/2020

10/07/2020

8:52 am

10/07/2020

8:55 am

Water

Water



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

FINAL REPORT

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090 Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini
Date Received: 10/07/2020
Date Final: 10/15/2020

Location: AE-16. Kitchenette Sink-Faculty Room C54

Sample ID: 2010-00220.016

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: Not Detected

Date Collected: 10/07/2020

Sample Type: Water Time Collected: 8:57 am

Status: Complete 10/15/2020

Location: AE-17. Kitchen Sink-Kitchen C57

Sample ID: 2010-00220.017

Test Requested: Environmental Culture Test-Legionella

Result: Not Detected

Date Collected: 10/07/2020

Sample Type: Water Time Collected: 8:59 am

Status: Complete 10/15/2020

Location: AE-18. Hot Water Heater-Mechanical Room D61

Sample ID: 2010-00220.018

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Date Collected: 10/07/2020

Sample Type: Water
Time Collected: 9:01 am

Time Collected: 9:01 au Status: Complete 10/15/2020

Result: Not Detected

Location: AE-19. Classroom Sink-Room D75

Sample ID: 2010-00220.019

Receipt Temp:

Receipt Temp:

Test Requested: Environmental Culture Test-Legionella

Result: **Positive**Concentration: 90.0 CFU/mL

Species: L. pneumophila, serogroup 6

Date Collected: 10/07/2020 Sample Type: Water

Time Collected: 9:04 am

Status: Complete 10/15/2020

Location: AE-20. Classroom Restroom Sink-Room A19

Sample ID: 2010-00220.020

Receipt Temp:
Test Requested: Environmental Culture Test-Legionella

Result: Positive

Concentration: 160.0 CFU/mL

Species: L. pneumophila, serogroup 6

Date Collected: 10/07/2020

Sample Type: Water

Time Collected: 9:05 am

Status: Complete 10/15/2020



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

FINAL REPORT

Account #: 5593

SPL Project ID: 2010-00220

Project Name: Acmetonia Elem. School

Sampled By: Amber Brancolini
Date Received: 10/07/2020
Date Final: 10/15/2020

AGX, Inc.

207 Pine Creek Road Wexford, PA 15090

Approved by: Marisa Hirsh

Janet E. Stout, Ph.D.

Laboratory Director, Special Pathogens Laboratory

NOTES

Environmental Culture Test-Legionella

- CFU/mL (or swab)=Colony Forming Units per milliliter or swab.
- -The limit of detection (LOD)* is approximately 0.5 -10 CFU/mL for Potable Water; 10 CFU/mL for Non-Potable Water (Cooling Towers); 1-10 CFU/mL for Hot Water Tanks; 20 CFU/swab for Swabs.
- * Sensitivity (LOD) may be affected if less than recommended sample volume is submitted for testing and if high concentration of non-Legionella bacteria are present in the sample. LOD values are mathematically derived according to the sample type, volume, and process.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria.
- -Probable identification. Contact laboratory if further identification by 16S sequencing required.
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days
- Samples should be analyzed within 2 days of collection.
- Accredited by the American Association for Laboratory Accreditation (Cert. No. 2847.01) and ELITE certified.
- Isolates saved upon request. Request must be received 1 week from receipt of report. Extra charges may apply.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.